

Emergency Engine Operational Limitations:

Unlimited use for emergencies (e.g. power outage, fire, flood);

100 hr/yr for maintenance/testing;

50 hr/yr of the 100 hr/yr allocation can be used for:

- Non-emergency situations if no financial arrangement
- Up to 15 of the 50 hr/yr can be used for emergency demand response